



# ENCLOSED FITTINGS

TECHNICAL BULLETIN - TBPL2023-01  
ENCLOSED FITTINGS  
DECEMBER 2023

In regard to enclosing Python fittings and couplers, please reference and follow the below section of IMC.

**IMC Section 1110.2 Exposure of refrigerant piping system: Refrigerant pipe and joints installed in the field shall be exposed for visual inspection and testing prior to being covered or enclosed.**

This means that you can enclose fittings and couplers within the piping system as long as these connection points have been visually pressure tested for leaks before enclosing.

FLEXIBLE | LIGHTWEIGHT / KINK-RESISTANT

T: 01509 508939 | E: [info@pythonls.com](mailto:info@pythonls.com)

