



# HORIZONTAL SUPPORT SPACING AND HANGERS

TECHNICAL BULLETIN - TBPL2023-02  
HORIZONTAL SUPPORT SPACING AND HANGERS  
DECEMBER 2023

The UMC Code states the following for refrigeration pipe supports:

## UMC 1109.6 Support:

In addition to the requirements of Section 1105.2, piping and tubing shall be securely fastened to a permanent support within 6 feet following the first bend in such tubing from the compressor and within 2 feet of each subsequent bend or angle. Piping and tubing shall be supported at points not more than 15 feet apart.

## Hanger:

A proper support is one that is designed as a pipe hanger, does not damage the line set during installation and provides full support.

FLEXIBLE | LIGHTWEIGHT / KINK-RESISTANT

T: 01509 508939 | E: [info@pythonls.com](mailto:info@pythonls.com)

